

## **NTETC Belt-Conveyor Scale Sector February 25, 2010 Meeting Summary**

### **A. NCWM Publication 14 Updates**

#### **1. HB-44, UR.3.2 (S&T Committee agenda item 321-1)**

**Background:** At the 2009 NCWM Annual Meeting, the Conference adopted an amendment to paragraph UR.3.2. to clarify that zero-load and material or simulated-load tests are required to be performed between official testing at intervals determined by the statutory authority or by the manufacturer. Full details of the amendments to NIST Handbook 44 may be found in the S&T Committee 2009 Interim Report.

**Discussion/Conclusion:** The Sector members agreed that this is a NIST Handbook 44 User Requirement and not intended for use during type evaluation. No changes are recommended in Publication 14.

#### **2. HB-44, S.1.3.1 (S&T Committee agenda item 321-3)**

**Background:** At the 2009 NCWM Annual Meeting, the Conference adopted an amendment to paragraph S.1.3.1. to reconcile the value of the minimum scale division (0.1 % of the minimum totalized load) with the value of the minimum test load (800 divisions) listed in paragraph N.2.3.(a).

**Recommendation:** NTETC Belt-Conveyor Sector Technical Advisor recommended the amendment to NCWM publication 14 section 1.8 as shown below to reflect changes in NIST Handbook 44 BCS Code, design specification S.1.3.1.

- 1.8. (S.1.2. and S.1.3.1.) *The scale division shall be in increments of 1, 2, or 5 times 10k where k is an integer **and shall not be greater than 0.125 % (1/800) of the minimum totalized load.*** Yes  No  N/A

1.8.1. *What is the scale division?*

<i>Unit</i>	<i>Abbreviation</i>
<i>pounds</i>	<i>lb or LB</i>
<i>U.S. short ton</i>	<i>ton or T</i>
<i>U.S. long ton</i>	<i>LT</i>
<i>Metric ton</i>	<i>t</i>
<i>kilograms</i>	<i>kg</i>

**1.8.2. Verify that the value of the scale division is protected by an acceptable security means (e.g., physical seal or audit trail).**

**Discussion/Conclusion:** Sector members agreed to recommend the proposed change to Publication 14 BCS section 1.8., and add a new section 1.8.2. to verify that the value of the scale division should be a sealable parameter which is protected by a security means as shown above.

### **3. HB-44 N.2., N.2.1. (S&T Committee agenda item 321-5) (Number of Tests during Initial Verification)**

**Background:** At the 2009 NCWM Annual Meeting, the Conference adopted an amendment to paragraph N.2.1. to provide clarification of how many test runs are required during an official test. Portions of the wording changes in N.2.1. relate to testing a belt-conveyor scale at a single flowrate (using a minimum of four test runs) if it can be verified that the system is operated using a single flowrate and that rate does not vary in either direction by an amount more than 10 % of the normal flow rate that can be developed at the installation for at least 80 % of the time.

These changes are applicable to specific installations that operate exclusively (within parameters) at one flowrate and would therefore not impact procedures used during type evaluation testing.

Other changes to N.2.1. will impact testing procedures regardless of the specifics of an installation and should therefore result in changes to Publication 14.

**Recommendation:** To reflect changes in the 2010 edition of NIST Handbook 44, the technical advisor recommends that Publication 14 page BCS-15 be amended as follows:

### 13. Field Test Procedure

Field Performance Test of the Belt-Conveyor Scale

~~N.2.1. Initial Verification.~~ A belt-conveyor scale system shall be tested at the normal use flow rate, 35 % of the maximum rated capacity, and an intermediate flow rate between these two points. The system may also be tested at any other rate of flow that may be used at the installation.  
(Added 2004)

**N.2.1. Initial Verification. – A belt-conveyor scale system shall be verified with a minimum of two test runs at each of the following flow rates:**

- (a) **normal use flow rate,**
- (b) **35 % of the maximum rated capacity, and**
- (c) **an intermediate flow rate between these two points.**

**Discussion/Conclusion:** The sector agreed to recommend the proposed amendments to Publication 14 BCS section 13. In addition the members also recommend that a note (as shown below) for section 13 be **added** to clarify that the site identified for conducting the field permanence test portion of the type evaluation shall be capable of providing tests at various flowrates.

**Note: The test site selected for permanence testing shall be capable of testing over a range of flow rates. Any site where the belt-conveyor scale system is limited to a single flow rate will not be considered acceptable.**

### 4. HB-44, T.1.1 (S&T Committee agenda item 321-6)

**Background:** At the 2009 NCWM Annual Meeting, the Conference adopted and amendment to paragraph T.1.1. Tolerance Values. to clarify the allowable change in zero during an official test. Background information on the amendments to Handbook 44 may be found in the S&T Committee 2009 Interim report.

**Recommendation:** The technical advisor recommended that no action is necessary because the amendments to Handbook 44 requirements shown above are applicable to subsequent field examinations, are not referenced explicitly in Pub 14, and do not apply to type approval test procedures,.

**Discussion/Conclusion:** Sector members agreed with the technical advisor's recommendation that no further actions are required.

## 5. **HB-44, Sections N.3.1.2., N.3.1.3., and S.3.3.1**

**Background:** At the 2009 NCWM Annual Meeting, the Conference adopted amendments to paragraphs N.3.1.2., N.3.1.3., N.3.1.4., and to add new paragraph S.3.1.1. in order to :

- Consolidate the requirements in N.3.1.2 and N.3.1.3,
- Clarify the testing guidelines in N.3.1.3.,
- Renumber the impacted paragraphs, and
- Add a new paragraph to state that the zero balance condition shall not be obscured by the automatic zero-setting mechanism.

**Recommendation:** The technical advisor recommended that references in Publication 14, pages BCS-16 be amended to reflect the consolidation and renumbering of the paragraphs as shown below:

### **13 Field Test Procedure**

~~**N.3.1.2. Initial Stable Zero.** The conveyor system shall be run to warm up the belt and the belt scale shall be zero adjusted as required. A series of zero load tests shall be carried out until three consecutive zero load tests each indicate an error which does not exceed  $\pm 0.06$  % of the totalized load at full scale capacity for the duration of the test. No adjustments can be made during the three consecutive zero load test readings.~~

~~(Added 2002) (Amended 2004)~~

**N.3.1.32. Test of Zero Stability.** - The conveyor system shall be operated to warm up the belt and the belt scale shall be zero adjusted as required. A series of zero-load tests shall be carried out **before weighing material** immediately before the simulated or materials test until the three consecutive zero-load tests each indicate an error which does not exceed  $\pm 0.06$  % of the totalized load at full scale capacity for the duration of test. No adjustments can be made during the three consecutive zero-load test readings.

(Added 2002) (Amended 2004 **and 2009**)

**N.3.1.43. Check For Consistency of the Conveyor Belt Along Its Entire Length.** - After a zero-load test with flow rate filtering disabled, the totalizer shall not change

more than plus or minus ( $\pm 3$  d) 3.0 scale divisions from its initial indication during one complete belt revolution.

(Added 2002) (Amended 2004)

The technical advisor also recommended adding the following language to Publication 14 page BCS-7:

## 6. Zero-Setting Mechanism

Code Reference: S.3.1. **and S.3.1.1.**

6.3. The completion of the automatic zero-setting operation must be indicated. Yes  No  N/A

**6.3.1 Verify that any changes in the zero reference are indicated and/or recorded** Yes  No  N/A

**Discussion/Conclusion:** The sector members agreed with the proposed changes and recommended that NCWM Publication 14 be amended as shown above.

## B. Proposed Update to NCWM Publication 14 Belt-Scale Checklist

**Background:** During the February 2009 BCS sector meeting, a draft Publication 14 checklist was developed and offered for use on a trial basis by NTEP labs that would evaluate manufacturer's replacement instruments. During the meeting, Sector Chairman, Bill Ripka of Thermo-Fisher stated that Thermo-Fisher would possibly have an instrument that would be submitted in the near future to undergo the NTEP process. This checklist could then be used on this instrument as a trial basis. The results/comments would then be returned to NTEP Administrator and Sector WG for review and further development. The entire draft checklist may be found in the 2009 NTETC Belt-Conveyor Scale Sector meeting summary.

**Discussion:** Based on information provided by NTEP Administrator Jim Truex, the sector members were informed that NTEP had not received an instrument from any manufacturer to use as a trial for the checklist that has been drafted. Lars Marmsater indicated that Merrick Industries will be submitting an indicator to update its NTEP Certificate of Conformance.

**Conclusion:** NTEP Administrator Jim Truex indicated that the California NTEP Lab would perform the evaluation when the device is submitted and that the sector will be provided with a report from the NTEP lab for any recommendations to approve or amend the proposed checklist. Sector members agreed that no further work is needed to the checklist at this time, pending a report from NTEP after applying the draft to the evaluation of an instrument. This item will be carried over and placed on the next meeting agenda of the NTETC BCS sector.

## C. Develop a List of Sealable Parameters for BCS Systems

**Background:** The list shown below was developed during the 2009 NTETC BCS Sector meeting and was to be forwarded to NTEP laboratories for use on a trial basis after which comments and recommended amendments would be forwarded to the Sector WG for further development. The technical advisor reported to the members that no manufacturers' devices have been submitted for NTEP approval and therefore the list has not been used during any evaluations.

**Discussion/Conclusion:** Sector members agreed that no further amendments to the table are needed at this time, and that the table should be incorporated in the 2011 edition of Publication 14.

<b>Belt-Conveyor Scale Features and Parameters</b>	
<b>Typical Features to be Sealed</b>	<b>Typical Features and Parameters Not Required to be Sealed</b>
Official verification zero reference Official verification span/calibration reference Linearity correction values Allowable range of zero (if adjustable) Selection of measurement units Division value, d Range of over capacity indications (if it can be set to extend beyond regulatory limits) Alarm limits for flow rate (high/low) Automatic zero-setting mechanism (on/off) Automatic zero-setting mechanism (range of a single step) Configuration (speed, capacity, calibrated test weight value if applicable, pulses per belt revolution, load cell configuration, )	Display update rate Baud rate for electronic data transfer Communications (Configuration of input, output signal to peripheral devices)
<p><i><b>NOTE:</b> The above examples of adjustments, parameters, and features to be sealed are to be considered "typical" or "normal." This list may not be all inclusive, and there may be parameters other than those listed which affect the metrological performance of the device and must, therefore, be sealed. If listed parameters or other parameters which may affect the metrological function of the device are not sealed, the manufacturer must demonstrate that the parameter will not affect the metrological performance of the device (i.e., all settings comply with the most stringent requirements of Handbook 44 for the applications for which the device is to be used).</i></p>	

## D. New Business

### 1. Revisit parameters used to categorize "Family" groups

Steve Cook, NIST recommended that the Sector review and revise if necessary the criteria used to base the grouping of instruments submitted for type evaluation as a Family or Type of devices. This topic is recommended to be included on the next NTETC Belt-Conveyor Scale Sector meeting agenda.

## E. Attendance

<b>2010 NTETC Belt-Conveyor Scale Sector Meeting Attendance</b>				
<b>Name</b>	<b>Company</b>	<b>Mailing Address</b>	<b>Telephone</b>	<b>Email</b>
John Barton	NIST	100 Bureau Dr. Mailstop 2600 Gaithersburg, MD 20899	301 975-4002	<a href="mailto:john.barton@nist.gov">john.barton@nist.gov</a>
Leonard Ian Burrell	Control Systems Technology	No. 3 Southern St. Oatley, NSW 2223 Australia	+61 4 1929-2604	<a href="mailto:iburrell@controlsystems.com.au">iburrell@controlsystems.com.au</a>
Steven Cook	NIST	100 Bureau Dr. Mailstop 2600 Gaithersburg, MD 20899	301 975-4003	<a href="mailto:stevenc@nist.gov">stevenc@nist.gov</a>
James Hale	Southern Co.	366 Three Oaks Subdivision Rd. Langley, KY 41645	606 285-3635	<a href="mailto:jahale@southernco.com">jahale@southernco.com</a>
Richard Harshman	NIST	100 Bureau Dr. Mailstop 2600 Gaithersburg, MD 20899	301 975-8107	<a href="mailto:richard.harshman@nist.gov">richard.harshman@nist.gov</a>
Ken Jones	CA. Division of Measurement Services	6790 Florin Perkins Rd., Suite 100 Sacramento, CA. 95828	916 229-3052	<a href="mailto:kjones@cdfa.ca.gov">kjones@cdfa.ca.gov</a>
Lars Marmsater	Merrick Industries, Inc.	10 Arthur Dr. Lynn Haven, FL 32444	850 271-7829	<a href="mailto:lars@merrick-inc.com">lars@merrick-inc.com</a>
Bill Ripka	Thermo Fisher Scientific	501 90th Ave. NW Minneapolis, MN.55433	800 445-3503	<a href="mailto:bill.ripka@thermofisher.com">bill.ripka@thermofisher.com</a>
Peter Serrico	Thayer Scale	91 Schoosett Street Pembroke, MA 02359	781 826-8101	<a href="mailto:psirrico@thayerscale.com">psirrico@thayerscale.com</a>
Chris Skelton	Control Systems Technology	37 Stanley Street Peakhurst Sydney, NSW 2210 Australia	+61 2 9584-4500	<a href="mailto:cskelton@controlsystems.com.au">cskelton@controlsystems.com.au</a>
James Truex	NCWM	88 Carryback Drive Pataskala, OH 43062	740 919-4350	<a href="mailto:jim.truex@ncwm.net">jim.truex@ncwm.net</a>
David Vaughn	Tennessee Valley Authority	1101 Market St. Chattanooga, TN 37402	423 751-3018	<a href="mailto:tdvaughn@tva.gov">tdvaughn@tva.gov</a>